

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LABORATORY
KOTTAYAM

Report on Analysis of WATER

Test Report No : 274/20-21

Date : 15/10/2020

Name : ST. Jude Global School, Thalappady, Puthuppally PO, Kottayam

Date of Receipt : 30/09/2020

Date of Testing : 30/09/2020

Sl No.	Characteristics	Unit	Desirable limits as per IS 10500 : 2012	Permissible limits	Actual Contents	Sampling Points
1	Turbidity (NTU)	NTU	1	5	1.6	1
2	pH		6.5-8.5	No relaxation	5.02	
3	Electrical Conductivity	µs/cm			50.6	
4	Acidity	mg/litre			12.0	
5	Alkalinity	mg/litre	200	600	20.0	
6	Sulphate (as SO4)	mg/litre	200	400	NIL	
7	Total Dissolved Solids(TDS)	mg/litre	500	2000	27.83	
8	Total Hardness as (CaCO3)	mg/litre	200	600	20.0	
9	Calcium (Ca)	mg/litre	75	200	6.40	
10	Magnesium (Mg)	mg/litre	30	100	0.97	
11	Chloride as (Cl)	mg/litre	250	1000	40.0	
12	Fluoride as (F)	mg/litre	1	1.5	NIL	
13	Iron (as Fe)	mg/litre	1	No relaxation	0.30	
14	Nitrate (as NO3)	mg/litre	45	No relaxation	NIL	

Sampling Points

1. ST. Jude Global School, Thalappady, Puthuppally PO, Kottayam

Remarks:

Low pH. Lime may be added to increase the pH.

Signature of Chemist

BACTERIOLOGICAL ANALYSIS

Sl No.	Source	Residual Chlorine in ppm	MPN of coliforms in 100 ml	MPN of E.Coli
1	ST. Jude Global School, Thalappady, Puthuppally PO, Kottayam	0.2	NIL	NIL

Remarks:

Signature of Bacteriologist

Signature of Asst. Engineer

For St Jude's Global School

[Signature]
Chairman



[Signature]
Principal

Principal
St. Jude's Global School
Thalappady, Puthuppally PO
Kottayam - 686 011

Due to Covid, there is a
 delay in renewal. *[Signature]*



പ്രാഥമിക ആരോഗ്യ കേന്ദ്രം, പുതുപ്പള്ളി

ഡി & ഓ ട്രേഡ് ലൈസൻസ് ലഭിക്കുന്നതിന് / പുതുക്കുന്നതിനുവേണ്ടി ബ്ലോം ഫ്ലോറൻസ്
..... (പേര്) സമർപ്പിച്ച അപേക്ഷയിന്മേലുള്ള അന്വേഷണ റിപ്പോർട്ടും
സാന്നിട്ടറി സർട്ടിഫിക്കറ്റ് / നിരാക്ഷേപപത്രവും പുതുപ്പള്ളി പഞ്ചായത്ത് സെക്രട്ടറിക്ക് സമർപ്പിക്കുന്നത്.

(REF : CIRCULAR NO: 66562/RC3/12 LSGD TVM DTD 10/01/2013)

അപേക്ഷകന്റെ പേര്	ബ്ലോം ഫ്ലോറൻസ്
പിതാവിന്റെ പേര് / ഭർത്താവിന്റെ പേര്	
വീട്ടുപേര്	ബ്ലോം ഫ്ലോറൻസ് ഫ്ലോറൻസ് ഫ്ലോറൻസ്
സ്ഥലം	തലപ്പാടി.
സ്ഥാപനത്തിന്റെ പേര്	ബ്ലോം ഫ്ലോറൻസ് ഫ്ലോറൻസ് ഫ്ലോറൻസ്
സ്ഥാപനം സ്ഥിതി ചെയ്യുന്ന സ്ഥലം	തലപ്പാടി.
സ്ഥാപനത്തിൽ നടത്തുന്ന വ്യാപാരങ്ങൾ	1. ഫുഡ് & ബേക്കറി അംഗീകാരം 2. 3.
നിലവിൽ ലൈസൻസ് ഉണ്ടെങ്കിൽ നമ്പർ	

സാക്ഷ്യപത്രം

പുതുപ്പള്ളി ഗ്രാമപഞ്ചായത്തിൽ II വാർഡിൽ കെട്ടിട നമ്പർ 396 ൽ ബ്ലോം ഫ്ലോറൻസ്
..... എന്നയാളുടെ ഉടമസ്ഥതയിലുള്ള ഫുഡ് & ബേക്കറി അംഗീകാരം
ഫുഡ് & ബേക്കറി അംഗീകാരം എന്ന പേരിലുള്ള സ്ഥാപനം പരിശോധിച്ച 2020-2021 വർഷത്തിൽ
പ്രവർത്തിക്കുന്നതിനാവശ്യമായ സാന്നിട്ടറി സർട്ടിഫിക്കറ്റ് നൽകിയതായി സാക്ഷ്യപ്പെടുത്തുന്നു. 1955 ലെ തിരുക്കൊച്ചി
പൊതുജനാരോഗ്യ നിയമവും നിലവിലുള്ള മറ്റ് നിയമങ്ങളും മറുപുറം സൂചിപ്പിക്കുന്ന നിബന്ധനകളും പാലിക്കാ
തിരിക്കുന്നത് ഈ സർട്ടിഫിക്കറ്റിനെ സ്വയമേവ അസാധുവാക്കുന്നതാണ്.

ഡി & ഓ ട്രേഡ് ലൈസൻസ് നൽകാവുന്നതാണ് / പുതുക്കാവുന്നതാണ്



[Signature]
ഹെൽത്ത് ഇൻസ്പെക്ടർ
HEALTH INSPECTOR


പ്രാഥമിക ആരോഗ്യ കേന്ദ്രം, പുതുപ്പള്ളി

ഡി & ഓ ട്രേഡ് ലൈസൻസ് പേർസണൽ

രജിസ്റ്ററിൽ ചേർത്തു നമ്പരും തീയതിയും :

314/2
22/3
2020-YAM-11

ജൂനിയർ ഹെൽത്ത് ഇൻസ്പെക്ടർ
For St Jude's Global School.



[Signature]

Principal
St. Jude's Global School,
Thalappady, Puthupally PO
Kottayam - 686 011

[Signature]
Chairman

Due to covid, there is a

delay in renewal. *[Signature]*